


Exova (UK) Ltd
Key Industrial Park
Fernside Road
Willenhall
West Midlands
WV13 3YA

T : +44 (0) 1902 722 122
F : +44 (0) 1902 727 242
E : willenhall@exova.com
W : www.exova.com



BS EN ISO 10077-1:2006



Calculation of: UK Door U Value

**Thermal Performance of Windows, Doors & Shutters –
Calculation of Thermal Resistance**

A Report To:
Debar Ltd

Whitehall Properties, Towngate, Wyke, Bradford, BD12 9JQ

Document Reference:
WIL 365055

Date: 15/06/2016

Copy: 1

Issue No.: 1

Page 1

**Testing
Advising
Assuring**

CONCLUSIONS

Drawings of:
Manufacturer Debar Ltd
Product DeWall A1
Model 3 Panel Slide Fold Doorset, Aluminium

Have been submitted for thermal performance calculation in accordance with BS EN ISO 10077-1:2006.

By Christian Adams, of Exova (UK) Ltd, a UKAS accredited Testing Laboratory (No. 0621) and EC Notified Body number (No. 1104)

At Key Industrial Park, Fernside Rd, Willenhall, West Midlands, WV13 3YA.
Results and comments as detailed below:

Description	U_D value $W/(m^2.K)$
Doorset 1 – 3 Panel Slide Fold Doorset 2500 x 2180mm	1.7

No inferences can be made regarding performance against other requirements of this standard

AUTHORISATION

Calculations performed by: Christian Adams, Thermal Test Engineer

Report issued by: Christian Adams, Thermal Test Engineer

Signed



Date 13th June 2016

For and on behalf of Exova (UK) Ltd

Report authorised by: Mark West, Door & Window Laboratory Manager

Signed



Date 13th June 2016

For and on behalf of Exova (UK) Ltd

Report issued: 15 June 2016



NOTE.

Tests marked "Not UKAS Accredited" are not covered by the Laboratory UKAS accreditation schedule.

Tests marked NT were not tested

Tests marked NA are not applicable to the product on test.

Exova (UK) Ltd is an EC Notified Body Number 1104

This report shall not be reproduced except in full, (and then only as permitted by copyright laws), without written approval from Exova (UK) Ltd.